

Notified Body No. 2812

Certificate of Constancy of Performance 2812-CPR-AC0007

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Grade 13 Stainless Steel Hinges See Annex A

Intended use: For use on fire/smoke compartmentation doors, and escape route doors

Essential characteristics	Performance	Harmonised technical specification		
Mechanical test evidence: 326 PCT, 879 PCT, WIL 356576, WIL 358929, WIL 407857, WIL 426993, WIL 435253, WIL 129696, WIL 420365 & WIL 535759 Fire Test Evidence: WF 345331, 20221215-002312 & WF 138907 Iss 11				
Self-closing Initial friction torque (door mass 120kg) Static load Load deformation	< 4Nm Passed with a displacement under load: lateral < 2mm vertical < 4mm and a residual displacement after unloading: lateral < 0.6mm vertical < 0.3mm 			
Overload Shear strength	- within the shaded area of figure G.1 Passed Passed with a lateral and vertical displacement after unloading < 3mm			
Hinges for use on fire-resistant and/or smoke-controls doors	Grade 1: suitable for use on fire/smoke resistant door assemblies	EN 1935:2002 / AC:2003		
Durability	Passed a 200,000 cycle test with a maximum wear: - lateral < 0.5mm - vertical < 1mm and with a maximum frictional torque after 20 cycles < 4Nm - after the completion of 200,000 cycles < 4Nm			
Families of hinges with common design features	The hinges covered by this certificate are listed in Annex A			
Corrosion resistance	Grade 4: 240 hours			
Dangerous substances	Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)			





Notified Body No. 2812

Certificate of Constancy of Performance 2812-CPR-AC0007

Placed on the market under the name of:

Royde & Tucker Limited
Bilton Road
Cadwell Lane
Hitchen,
Hertfordshire
SG4 0SB
United Kingdom

and produced in the manufacturing plant:

CQB28702-1

This is coded format, and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

EN 1935:2002 / AC:2003

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **24/11/2020** and re-issued on **06/02/2025** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: 23/07/2025

ERO Project Reference: ERO 034621 P1700

Pascal Coget General Manager – European Certification

CSF408-NL .0





Notified Body No. 2812

Certificate of Constancy of Performance 2812-CPR-AC0007

Annex A

Model Reference	Description	
H102-7-FR-BSS	100 x 82 x 3mm stainless steel hi-load interleaf flush hinge Brushed stainless steel Radiused corner	
H200-FR-BSS	102 x 95 x 3.25mm stainless steel butterfly hinge Brushed stainless steel finish Radiused or square corners	
H207-FR-BSS	102 x 76 x 3mm stainless steel concealed bearing butt hinge Brushed stainless steel finish Radiused or square corners	
H208-FR-BSS	102 x 89 x 3mm stainless steel concealed bearing butt hinge Brushed stainless steel finish Radiused or square corners	
H209-FR-BSS	102 x 102 x 3mm stainless steel concealed bearing butt hinge Brushed stainless steel finish Radiused or square corners	
H210-FR-BSS	114 x 102 x 3.3mm stainless steel concealed bearing butt hinge Brushed stainless steel finish Radiused or square corners	
H605-FR-BSS	185 x 32 x 34mm stainless steel hi load concealed hinge Brushed stainless steel	

	SS316 stainless steel hinges av	ailable in t	the following finishes:
316B	Satin brushed stainless steel	316P	Polished stainless steel
	SS304 stainless steel hinges av		
BSŞ	Satin brushed stainless steel	PSS	Polished stainless steel
ABR	Antique brass	RBZ	RT bronze
ABZ	Antique bronze	SBB	Simulated brushed brass
BLK	Black powder coated	SBL	Simulated brass, lacquered
BNP	Bright nickel plated	SNP	Satin nickel plated
DBZ	Dark bronze	SPB	Simulated polished brass
EBP	Electro brass plated	WHI	White paint powder coat
FMB	Flat matt black powder coat	XABR	Antique brass variant
IBU	Imitation bronze	XBNP	Bright nickel plated variant
NST	Non-standard painted	XDBZ	Dark bronze variant
NSTP	Non-standard plated	XIBU	Imitation bronze variant
OBZ	Old bronze	XOBZ	Old bronze variant
PBL	Polished brass plated, lacquered	XRBZ	RT bronze variant
PBZ	Polished bronze	XSNP	Satin nickel plated variant
PNP	Polished nickel plated	XSPB	Simulated polished brass variant
PVD	PVD		

